



# STIRLING FIRE PROTECTION LTD

Quality Equipment maintained to British Standards



## Certificate of Inspection

Castle Walk Guest House  
4 Back Walk  
Stirling FK8 2QA  
Jackie Hadland O7598029732  
6 6 CASTLE02

SERVICE DATE July 2023 EXPIRY July 2024

The Fire Extinguishers were serviced in accordance with BS 5306 3.  
This is in compliance with the Fire Precautions (Workplace)  
Regulations 1997 and the Fire (Scotland) Act 2005.

Technician's Name Alan Jamieson

Technician's Signature A Jamieson

Tick if non conforming equipment is left on site (*see over*)  
*For extinguisher locations see over or location report*

Monthly inspections should be carried out by the user to ensure  
that the extinguishers are in the correct locations, Pins and Seals are in place.  
No apparent damage to the extinguisher and the gauge (if fitted)  
is in the green sector